



NOTE:

1. WHERE FIRE HYDRANT IS SHOWN BEHIND SIDEWALK, SET CENTER OF HYDRANT 2'-0" BEHIND WALK.

APPROVED: SCOTT THOMASSON

REV. DATE: NOV. 01, 2005

WATER/WASTEWATER DIVISION



STANDARD DETAILS

FIRE HYDRANT ASSEMBLY

FILE SD713.DGN DRAWING NO. 713